

<b>7</b>	<b>BILL No.7:</b>				
	<b>MOFOLO CLINIC</b>				
	<b>The UPS system consist of 2x 12kVA Riello UPS. Both UPS require a MINOR service. The service will include the following:</b>				
<b>Item</b>	<b>Description</b>	<b>Unit</b>	<b>Qty</b>	<b>Rate</b>	<b>Amount</b>
7.1	<b>UPS MINOR service</b>				
7.1.1	Download event History	no.	2		
7.1.2	Upgrade firmware to latest revision	no.	2		
7.1.3	Cleaning of the UPSs	no.	2		
7.2	<b>Replacement of batteries</b>				
7.2.1	Test the existing batteries to verify their efficiency for both UPSs	sum	1		
7.3	<b>Commissioning</b>				
7.3.1	Commissioning the two systems complete in the presence of the Engineer	sum	1		
7.4	<b>Miscellaneous</b>				
7.4.1	Clean the floor (only the UPS room ) to ensure the room is neat and in good condition.	sum	1		
7.5.	<b>CoC (Only for UPS Output DB)</b>	no.	1		
7.6	Supply a Service record book with two carbon copies	no.	1		
7.7	Service of the Air Condition Unit	Sum	1		
7.8	Provide Red top (shaved earth) plug top leads	No.	20		
7.9	Professional fees ( 15%, exclude P&Gs and Contingency)	%	0.15		
	<b>Total for Bill No 7: Mofolo Clinic Forward to Bill of Quantities Summary Page</b>				